

CERTIFICATE

Issued to:
Applicant:
Bachmann GmbH & Co. Kg
Ernstaldenstr. 33, 70565 Stuttgart-Vaihingen,
Germany

Manufacturer/Licensee:
Bachmann GmbH & Co. Kg
Ernstaldenstr. 33, 70565 Stuttgart-Vaihingen,
Germany

Product(s) : portable socket-outlets (2-pole)
Trade name(s) : BACH MANN
Type(s)/model(s) : 931.000, 931.001

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standards IEC 60884-1:2002 + A1:2006; DIN VDE 0620-1:2010; NEN 1020:1987 + A2:2004
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 900507

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.


This certificate is issued on: 6 November 2012 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 4309041.01

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



Bengo Mo
Certification Manager

© Integral publication of this certificate is allowed

All testing, inspection, auditing and certification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group.

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product	:	portable socket-outlets (2-pole)
trade name(s)	:	BACHMANN
type(s)	:	931.000 931.001
rated current	:	16 A
rated voltage	:	250 V~
earthing	:	with side earthing-contacts
design	:	non-rewirable; safety socket-outlet (with shutters)
method of application	:	special design for build-in office furniture
standard sheet	:	-III of CEE 7 -DIN 49440-1
applied flexible cord	:	H05VV-F 3G1,5 mm ²
certification mark	:	KEMA-KEUR
cord termination	:	soldered connections
description	:	body of thermoplastic material, provided with a rotatable metal cover
markings	:	are shown on the body

List of components

component	trade name	type/model	approval mark
flexible cable	Jiefei	H05VV-F	VDE
flexible cable (alternative)	Various	H05VV-F	KEMA-KEUR or VDE certified
plug	BACHMANN	30	KEMA-KEUR
plug (alternative)	BACHMANN	31M	VDE
plug-connector (alternative)	Wieland	GST18I3SS1	VDE

Product data-type 931.000

design : double socket-outlet

Product data-type 931.001

design : single socket-outlet

TESTS**Test requirements**

- IEC 60884-1:2002 + A1:2006
- DIN VDE 0620-1: 2010
- NEN 1020:1987 + A2:2004

Test results

The test results are laid down in DEKRA test file 4309041.01

Conclusion

The examination proved that all test requirements were met.

Tested by : Allen Han



Checked by : J.C. Hendriksen

**FACTORY-LOCATION**

Active Enterprises Limited

Ben Men Ind Zone Heng Keng, Liao Bu, Dong Guan City, Guang Dong, China